

CERTIFICATE

of conformity with the following European Directives

Low Voltage Directive 2014/35/EU

This certifies that below described products of the applicant:

BLUESUN SOLAR CO.LTD

**BUILDING NO.7, 1499 ZHENXING ROAD SHUSHAN DIST. 230031
HEFEI CHINA**

comply to the essential requirements of the above mentioned European Directive and the following standards, taking into account the German national deviations:

Product(s): Grid-Connected PV Inverter

Model type(s): BSM75K-B2, BSM75K-B3, BSM100K-B, BSM110K-B, BSM110K-B1, BSM110K-B2, BSM110K-B3, BSM125K-B, BSM125K-B1, BSM125K-B2, BSM125K-B3, BSM125K-B5, BSM125K-B6, BSM125K-B7, BSM125K-B8, BSM125K-B9

This certificate of conformity is based on the evaluation of samples of the product. It does not imply an assessment of the production and it does not permit the use of a mark of conformity or of a safety mark of the TÜV NORD CERT GmbH. The holder of this certificate may use this Certificate together with his EC-Declaration of Conformity. The CE marking may be affixed on the product if all relevant and effective Directives are complied with, under full responsibility of the holder.

Certification program: P33-VA-01 Rev. 02 / 04.20
Certification fundamental(s): IEC 62109-1:2010; IEC 62109-2:2011
Registered no.: 44 799 24 406749 - 277
Report no.: 492013301.001
File no.: PVP06086/24B-04



TÜV NORD CERT GmbH
Certification Body
Balance of System (BOS) for Photovoltaics

Essen, 2024-08-06

ANNEX

Annex 1, Page 1 of 3

to Certificate registration no. 44 799 24 406749 - 277

Description of product(s):

Model	BSM75K-B3	BSM75K-B2	BSM100 K-B	BSM110 K-B	BSM110 K-B1	BSM110 K-B2	BSM110 K-B3
PV terminal							
Vmax [V d.c.]	800	1100					
MPP voltage range [V d.c.]	200-800	200-1000					
Isc [V d.c.]	60	60	48	60	48	60	60
I _{max} [V d.c.]	45	45	32	45	32	45	45
Number of MPPT tracking	9	8	9	6	9	8	7
String of each MPPT	2	2	2	3	2	2	2
AC terminal							
Rated output voltage [V a.c.]	127/220, 3W+PE(+N)	220/380, 3W+PE(+N)	230/400, 3W+PE(+N)				
Rated output frequency [Hz]	50/60						
Rated output current [A a.c.]	196.9	113.7	144.9	159.4	159.4	159.4	159.4
Max. output current [A a.c.]	196.9	113.7	159.4	175.4	175.4	175.4	175.4
Rated output power [kW]	75	75	100	110	110	110	110
Max. apparent power[kVA]	75	75	110	121	121	121	121



TÜV NORD CERT GmbH
 Certification Body
 Balance of System (BOS) for Photovoltaics

Essen, 2024-08-06

ANNEX

Annex 1, Page 2 of 3

to Certificate registration no. 44 799 24 406749 - 277

Power factor	0.8 lagging to 0.8 leading
General	
Ambient temperature [°C]	-30 ~60
Ingress protection	IP66
Protective class	I
Firmware version	DSP1: V0.1.0, DSP2: V1.3.0, ARM: V3.0.0

Model	BSM1 25K-B	BSM1 25K- B1	BSM1 25K- B2	BSM1 25K- B3	BSM1 25K- B5	BSM1 25K- B6	BSM1 25K- B7	BSM1 25K- B8	BSM125K- B9
PV terminal									
Vmax [V d.c.]	1100								
MPP voltage range [V d.c.]	200-1000								
Isc [V d.c.]	60	48	60	60	60	48	60	60	60
I _{max} [V d.c.]	45	32	45	45	45	32	45	45	45
Number of MPPT tracking	6	9	8	7	6	9	8	7	8
String of each MPPT	3	2	2	2	3	2	2	2	2
AC terminal									



TÜV NORD CERT GmbH
 Certification Body
 Balance of System (BOS) for Photovoltaics

Essen, 2024-08-06

ANNEX

Annex 1, Page 3 of 3

to Certificate registration no. 44 799 24 406749 - 277

Rated output voltage [V a.c.]	230/400, 3W+PE(+N)								220/380, 3W+PE(+N)
Rated output frequency [Hz]	50/60								
Rated output current [A a.c.]	181.2	181.2	181.2	181.2	181.2	181.2	181.2	181.2	189.4
Max. output current [A a.c.]	199.3	199.3	199.3	199.3	181.2	181.2	181.2	181.2	197.0
Rated output power [kW a.c.]	125	125	125	125	125	125	125	125	125
Max. apparent power[kVA a.c.]	137.5	137.5	137.5	137.5	125	125	125	125	130
Power factor	0.8 lagging to 0.8 leading								
General									
Ambient temperature [°C]	-30 ~60								
Ingress protection	IP66								
Protective class	I								
Firmware version	DSP1: V0.1.0, DSP2: V1.3.0, ARM: V3.0.0								

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex of test report.



TÜV NORD CERT GmbH
 Certification Body
 Balance of System (BOS) for Photovoltaics

Essen, 2024-08-06